



Number	100521/01	Replaces	--
Issued	2019-01-15	Scope	AR 165
Contract number	Q12/004	Page	1-2

Product Certificate

## Gas meter brackets

Based on pre-certification tests as well as periodic inspections by Kiwa Nederland B.V., the products referred to in this certificate and marked with the GASTEC QA mark, supplied by

### gAvilar B.V.

may, on delivery, be relied upon to comply with the GASTEC QA Approval Requirements 165, for "Metal gas meter brackets", dated December 2016.

Ronald Karel  
Kiwa

This certificate is issued by Kiwa Nederland B.V. in conjunction with the KIWA regulations for Certification 2017.

This certificate consists of 2 pages.  
Publication of the certificate is allowed.

# CERTIFICATE

Kiwa Nederland B.V.  
Sir. Winston Churchillaan 273  
P.O. Box 70  
2280 AB RIJSWIJK  
The Netherlands  
Tel. +31 88 998 4400  
[info@kiwa.nl](mailto:info@kiwa.nl)  
[www.kiwa.nl](http://www.kiwa.nl)

**supplier**  
gAvilar B.V.  
Kam. Onnesweg 63  
3316 GK Dordrecht  
P.O. Box 3078  
3301 DB Dordrecht  
[www.gavilar.nl](http://www.gavilar.nl)

T +31 (0) 85-4897130  
F +31 (0) 85-4897140



Number	100521/01	Replaces	--
Issued		Scope	AR 165
Contract number	Q12/004	Page	2-2

## Gas meter brackets

---

### PRODUCT SPECIFICATION

Gas meter bracket suitable for a gas meter G10 or G16

- With or without pressure regulator
- Inlet connection size G 1½" union nut
- Outlet connection size R 1¼"

Gas meter bracket suitable for a gas meter G25

- With or without pressure regulator
  - Inlet connection size G 1½" or G 2" union nut
  - Outlet connection size R 1½"
- 

### APPLICATION AND USE

These criteria apply on metal gas meter brackets for stress-free mounting of gas meters for the use of 1<sup>st</sup>, 2<sup>nd</sup> and 3<sup>rd</sup> family gasses according to NEN-EN 437.

---

### MARKING

- GASTEC QA trademark.
  - Manufacturers name or trademark: gAvilar
  - Nominal connection size of the gas meter
  - Maximum working pressure 200 mbar
  - Year and week number of manufacture or the manufacturing number: date + batch number
- 

### RECOMMENDATIONS FOR END USERS

Check at the time of delivery whether:

- the producer has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport.

Consult the producer's processing guidelines for the proper storage and transport methods.

Check whether this certificate is still valid by consulting Kiwa Nederland B.V. or the Kiwa website.

If you should reject a product on the basis of the above, please contact the supplier and, if necessary, Kiwa Nederland B.V.

---