

Number	67766/01	Replaces	-
Issued	1 May 2012	Scope	KE 88
Report number	115405	Page	1-2
Contract number	Q12/004		


Product Certificate

Low pressure cut-off valves

Based on pre-certification tests as well as periodic inspections by Kiwa Nederland B.V., the products referred to in this certificate and marked with the GASTEC QA mark, supplied by

gAvilar B.V.

may, on delivery, be relied upon to comply with the Gastec QA Approval Requirements 88, for "Low pressure cut-off valves, nominal pressure 25 mbar, dated 01 may 1990.



Bouke Meekma
Kiwa

This certificate is issued by Kiwa Nederland B.V. in conjunction with the "KIWA regulations for carrying the GASTEC QA quality mark".

This certificate consists of 2 pages.
Publication of the certificate is allowed.

Page	2	Number	67766/01	Replaces	-
		Issued	1 May 2012	Scope	KE 88
		Report number	115405	Page	2-2
		Contract number	Q12/004		

Low pressure cut-off valves

PRODUCT SPECIFICATION

Automatic working low pressure cut-off valve, nominal pressure 25 mbar, inlet pressure 100 mbar en and a nominal capacity of 6 m³/h.

WMG 6-MV-W 3/4"	with detector. Connection in- outlet GM 3/4".
WMG 6-ZV-W 3/4"	As type WMG 6 MV-W 3/4", without detector.
WMG 6-MV	with detector. Connection in- outlet Rp 3/4".
WMG 6-ZV	As type WMG 6 MV, without detector.
WMG 6-F-ZV	Without detector. Flange connection
WMGI 6 long	Connection inlet Rp 3/4" outlet W 3/4".

APPLICATION AND USE

Low pressure cut-off valves, nominal pressure 25 mbar, are used as safety device in gas installations according NEN 1078.

MARKING

- Manufacturer's name or trademark.
- Function and type indication (Low pressure cut-off valve for natural gas).
- Year and week number of manufacture or the manufacturing number (The year and week number can be processed as a code in the manufacturing number).
- Nominal capacity in m³/h.
- Nominal pressure 25 mbar.
- The products are marked with GASTEC QA quality mark.

Place of the mark:

- On the body of the valve in a clearly visible position.

Method of marking:

- **Non-erasable.**

RECOMMENDATIONS FOR CUSTOMERS:

1. Check at the time of delivery whether:
 - 1.1 the producer has delivery in accordance with the agreement;
 - 1.2 the mark and the marking method are correct;
 - 1.3 the products show no visible defects as a result of transport etc.
 2. If you should reject a product on the basis of the above, please contact:
 - 2.1 gAvilar B.V.
and, if necessary,
 - 2.2 Kiwa Nederland B.V.
 3. Consult the producer's processing guidelines for the proper storage and transport methods.
 4. Check whether this certificate is still valid by consulting the publication list for Gastec Certificates (Kluwer Handboek).
-