



# DECLARATION



Declaration  
of Performance 106761/01  
Conformance certificate 67765  
Conformance report 200601828  
Date 01-01-2021  
Replaces : -

## Declaration of Performance

Declaration of performance to AR 214

Kiwa Nederland B.V. declares that, the Gas pressure regulators and low pressure cut-off valves manufactured by

**gAvilar B.V.**

complies with the applicable requirements of:

Approval requirement 214: "Fitness for admixtures up to and including 100% hydrogen gas"; 2019

### Remarks

The following products are covered under this declaration of performance:

- Gas pressure regulators for domestic installations with an inlet pressure up to 200 mbar, nominal capacity of 80%CH<sub>4</sub>/20%H<sub>2</sub> 10 Sm<sup>3</sup>/h and 100% H<sub>2</sub> 30 Sm<sup>3</sup>/h – Type WMR

This declaration consists of one page.

Ron Scheepers  
Kiwa

Kiwa Nederland B.V.  
Wilmersdorf 50  
P.O. Box 137  
7300 AC APELDOORN  
The Netherlands  
Tel. +31- 55 539 33 55  
Fax +31- 55 539 36 76  
[www.kiwa.nl](http://www.kiwa.nl)

**Manufacturer**  
gAvilar B.V.  
Kam. Onnesweg 63  
3316 GK Dordrecht

[www.gavilar.nl](http://www.gavilar.nl)

T +31 (0) 85-4897130  
F +31 (0) 85-4897140